

DISTRICT BOARD OF TRUSTEES  
PENSACOLA JUNIOR COLLEGE  
1000 COLLEGE BOULEVARD  
PENSACOLA, FL 32504-8998

July 5, 2007

ADDENDUM NO. 1  
TO  
INVITATION TO BID (ITB) 12 - 2006/2007 FOR CAMPUS SIGNS, FABRICATION & INSTALLATION  
FOR  
PENSACOLA JUNIOR COLLEGE

The following is in response to vendor questions resulting from the pre-bid conference on July 3, 2007:

**Page 4, Specifications: Slat & Post Signs:**

- Distance from bottom of sign to ground: 30 inches – top height of all signs will be the same: approximately 78 inches.
- Aluminum sign posts shall be baked enamel and polyurethane (please specify which one on bid sheet)
- Posts and Slats shall be painted in PMS 343 Green
- All signs shall be anchored in concrete
- All signs shall be aluminum box type post and panel with extruded word bars.
- All signs shall be a minimum of 0.080 gauge aluminum (please specify gauge on bid sheet)
- Signs A – H shall be constructed on one single slat – PJC Logo on the single slat
- Signs I – V shall have the PJC Logo on an 8” top slat with 6” lettering
- Signs I – V shall have all other slats 5” wide with 3” lettering
- Vendor will not have to pull permits
- PJC will identify location of underground utilities

**Page 4, Specifications: Number Signs**

- Building numbers shall be baked enamel or anodized aluminum (please specify on bid sheet)
- All removed numbers will remain the property of PJC (unless damaged upon removal)
- PJC will make necessary cosmetic repairs to buildings after numbers removed

**Page 4, Specifications: Campus Map Holder**

- PJC will furnish the map for insertion into the map holder (cabinet)

See Revised Attachments A & B and Bid Sheet (must be returned with bid)

All other specifications remain the same. The estimated completion date for this project is September 30, 2007.

Angie C. Jones  
Director of Purchasing  
and Auxiliary Services

Please acknowledge and return this addendum with your bid. If you have already submitted a bid, please return this addendum, with signed acknowledgment, by the bid opening deadline, July 17, 2007. Addendum can not be faxed.

ADDENDUM ACKNOWLEDGED BY: \_\_\_\_\_  
FIRM/ENTITY \_\_\_\_\_  
SIGNATURE OF REPRESENTATIVE: \_\_\_\_\_